



NOTES:

1. 1 1/2" CORP STOP MAY BE DIRECT TAPPED TO 16" AND LARGER MAINS.
2. THE DISTANCE BETWEEN RUNGS, CLEATS AND STEPS SHALL NOT EXCEED 12 INCHES AND SHALL BE UNIFORM THROUGHOUT THE LENGTH OF THE LADDER.

DENVER WATER

1600 West 12th Avenue • Denver, Colorado 80204
Phone (303) 628-6000 • Telecopier No. (303) 628-6851

CONDUIT OR TRANSMISSION MAIN, MECHANICAL JOINT OF FLANGED BUTTERFLY VALVE INSTALLATION

Scale: NONE Date: JUNE 1995

Drawn: C.B.B. Tr: Ck:

Approved: [Signature] Dr. 127 No. 35